Verified RealEstate™

RE REGULATORY RECORD

RERA Document

The document as the regulator published it, reproduced in full behind this page.

Published for reference. The authority's own register is the operative record.

Verified RealEstate™
3/350/2 Mettukuppam,
OMR Thoraipakkam,
Chennai 600 097, India

hello@verified.realestate
+91 9996 12 9996
verified.realestate

DIGITALLY VERIFIED RECORD

Report on

The Geotechnical Investigation for the Proposed Construction of Residential Group Development Villas Building in S.F. No: 514/1A1, 1A2, 518/2B, 2C & 519/2B at Vadavalli Village, West Zone, Perur Taluk, Coimbatore Corporation.

CLIENT:

M/s. Promag Foundations and Structures Private Limited,
M/s. SGK Investment Trust (POA),
F-1, First Floor, Srivari Kikani Centre,
No.2, Krishnaswamy Road,
Coimbatore.

Project Code: 102419

16 November 2024

GEOCARE ENGINEERING CONSULTANCY
(An ISO 9001:2015 Certified Company)
#17/25B, Annur Road,
Karumathampatti, Coimbatore - 641 659.
Phone: 0422-3592569
Mobile: 9597262815
email: geocareconsultancy@gmail.com

SGK INVESTMENT TRUST

GEOTECHNICAL INVESTIGATION BY STANDARD PENETRATION TEST (SPT)

Client Name	M/s. Promag Foundations and Structures Private Limited, M/s. SGK Investment Trust (POA),
Client Address	F-1, First Floor, Srivari Kikani Centre, No.2, Krishnaswamy Road, Coimbatore - 641 002.
Project	Proposed Construction of Residential Group Development Villas Building
Site Address	S.F. No: 514/1A1, 1A2, 518/2B, 2C & 519/2B, Vadavalli Village, West Zone, Perur Taluk, Coimbatore Corporation.
Date of field test	24th October 2024

Field test conducted by	S. Mani, B.E
Report Prepared by	R. Suresh, B.E
Report Verified by	R. Sathishkumar, M.E (Geotech) / S. Prabhavathi, M.E (Geotech)
Report Approved by	R. Sathishkumar, M.E (Geotech)

GEOCARE Engineering Consultancy CBE-659

For PROMAG FOUNDATIONS AND STRUCTURES PRIVATE LIMITED,

Authorised Signatory

Proprietor / Partner / Director

For SGK INVESTMENT TRUST

SGK

Authorized Signatory

GEOTECHNICAL INVESTIGATION FOR THE PROPOSED CONSTRUCTION OF RESIDENTIAL GROUP DEVELOPMENT VILLAS BUILDING IN S.F.NO: 514/1A1, 1A2, 518/2B, 2C & 519/2B AT VADAVALLI VILLAGE, WEST ZONE, PERUR TALUK, COIMBATORE CORPORATION.

INTRODUCTION

The Management, M/s. Promag Foundations and Structures Private Limited, M/s. SGK Investment Trust (POA), proposes to construct a Residential Group Development Villas Building in S.F. No: 514/1A1, 1A2, 518/2B, 2C & 519/2B at Vadavalli Village, West Zone, Perur Taluk, Coimbatore Corporation. In order to enable an adequate and economic design the Geotechnical Investigation was assigned to M/s. GEOCARE Engineering Consultancy, Coimbatore in view to furnish the detailed technical information of the nature of subsoil strata for detail analysis and foundation designs.

SAMPLING METHODOLOGY

To study the subsoil strata at the proposed location 05 nos. of 5' x 5' (approx.) size pit were excavated at specified location based on client's suggestion to carry out the Standard Penetration Test (SPT).

STANDARD PENETRATION TEST

Standard Penetration Test (SPT), which is done to determine penetration resistance was conducted in the trial pit using the procedure as described in IS: 2131. In this method, split spoon sampler (50.8mm OD and 35mm ID) is driven by dropping 63.5kg weight with a free fall of 75cm. The length of the sampler is 60cm. The sampler is first driven through 15cm as a "seating drive ". It is further driven through 30cm. The number of blows required for drilling the sampler for next 30 cm beyond seating drive is termed as "penetration resistance," N".

The samples thus recovered were transported to the laboratory for further investigation if necessary.

SOIL PROFILE AND STRATA

Based on the visual inspection carried out at the site, the subsoil strata at TP1 to TP5 consists of Top Filled Soil up to a depth of about 0.40m below existing ground level (EGL), followed by Clay up to a depth of about 0.50 – 1.10m, Clayey Gravel up

For PROMAG FOUNDATIONS AND STRUCTURES PRIVATE LIMITED
Authorised Signatory

GEOCARE Engineering Consultancy CBE-659

For SGK INVESTMENT TRUST
Project Code: 102419
SGK
Authorized Signatory

to a depth of about 1.0 – 1.50m, Sandy Gravel up to a depth of about 1.60 – 2.80m and underlain by Dense Gravel at explored depth.

Stratum I	:	Top Filled Soil
Stratum I	:	Clay
Stratum II	:	Clayey Gravel
Stratum III	:	Sandy Gravel
Stratum IV	:	Dense Gravel

Test Pit No.	Strata depth in m				
	Stratum I	Stratum II	Stratum III	Stratum IV	Stratum V
TP1	0.0 – 0.40	-	0.40 – 1.50	1.50 – 2.60	2.60 and above
TP2	-	0.0 – 1.10	-	1.10 – 2.0	2.0 and above
TP3	-	0.0 – 0.50	0.50 – 1.0	1.0 – 1.60	1.60 and above
TP4	-	0.0 – 0.50	0.50 – 1.0	1.0 – 2.80	2.80 and above
TP5	-	0.0 – 0.80	0.80 – 1.40	1.40 – 2.20	2.20 and above

NET SAFE BEARING CAPACITY/ALLOWABLE BEARING PRESSURES

The N Values from SPT at respective depths are given below. Bearing capacity has been determined based on N Value. Recommendations are provided at depth of **1.60m, 2.20m & 2.80m**

For SGK INVESTMENT TRUST

Authorized Signatory

For PROMAC FOUNDATIONS AND STRUCTURES PRIVATE LIMITED

Authorised Signatory

GEOCARE Engineering Consultancy CBE-659

Table-1 Allowable Safe Bearing Capacity				
Test Pit No.	Depth below EGL (m)	Type of Strata	N Value	SBC (kN/m²) B=1.5m
TP1 & TP4	2.80	Dense Gravel	>50	340
TP2 & TP5	2.20			300
TP3	1.60			270

CONCLUSION & RECOMMENDATION

- The subsoil consists of Top Filled Soil, Clay, Clayey Gravel, Sandy Gravel and underlain by Dense Gravel at explored depth.
- Based on the investigation on the subsoil profile, open foundation of **isolated / combined footing** with tie beam is recommended.
- The recommended SBC for depth of foundation **2.80m** below EGL is **340kN/m²** considering TP1, TP4 for a footing width of **1.50m.**
- The recommended SBC for depth of foundation **2.20m** below EGL is **300kN/m²** considering TP2, TP5 for a footing width of **1.50m.**
- The recommended SBC for depth of foundation **1.60m** below EGL is **270kN/m²** considering TP3 for a footing width of **1.50m.**
- However, the footing shall be rested at the dense strata (Dense Gravel) irrespective of the recommended depth. If strata occurs at earlier depth and respective SBC shall be considered since depth variation of strata is there.
- Over-excavation and loosening of strata at the founding level shall be avoided. Same if done shall be replaced by lean concrete.
- Prior to laying PCC, all loose soil in the foundation shall be removed and the base should be thoroughly compacted.
- It is recommended that the back filling in the foundation should be carried out with proper compaction.

For PROMAC FOUNDATIONS AND STRUCTURES PRIVATE LIMITED,
Authorised Signatory

For SGK INVESTMENT TRUST
Authorized Signatory

- If there is any profile variation or to get the subsoil profile up to the desired depth rotary drilling method may be adopted.

- Recommendations given are based on the assumption that same strata or harder strata extends below the explored depth.

- Interpretations are provided based on factual field results & shall be applicable for investigated locations. There is a possibility that strata variations could occur. If any variations indicate significant deviation from the findings of this report, same shall be brought to our notice

For

GEOCARE ENGINEERING CONSULTANCY

Authorized Signatory

Er. R.SATHISHKUMAR
M.E.(Geotech)., M.I.G.S., A.M.I.E., M.I.S.T.E.,
Registered Geotechnical Engineer
Reg. No: Coimbatore District/GTE/01/2025
No: 17/25-B, Annur Road, Karumathampatti
Coimbatore - 641 659
Ph: 0422-3592569 Mob: +91 9597262815

GEOCARE Engineering Consultancy CBE-659

For PROMAG FOUNDATIONS AND STRUCTURES PRIVATE LIMITED

Authorised Signatory


For SGK INVESTMENT TRUST

Authorized Signatory


PHOTOGRAPHS SHOWING FIELD INVESTIGATION




Trial Pit - 02



Trial Pit - 03



Trial Pit - 04



Sample collection TP - 05

For PROMAC FOUNDATIONS AND STRUCTURES PRIVATE LIMITED

Authorised Signatory

For SGK INVESTMENT TRUST

Project Code: 102419

Authorized Signatory

SITE LOCATION



GEOCARE Engineering Consultancy
CBE-659

For PROMAC FOUNDATIONS AND STRUCTURES PRIVATE LIMITED

Authorised Signatory

For SGK INVESTMENT TRUST

Authorized Signatory

THE LANDLENS SUITE

Eight ways to know a piece of land before you pay for it.

This report covers one part of the picture. These cover the rest, drawn from the same government records, for any property in Tamil Nadu.

LandLens One
Ask anything about a property and get an answer grounded in live government records, with the sources shown.
/landlens/one

Verify My Land
Every record check run on one property and returned as a single report.
/landlens/verify-my-land

Legal Opinion
An advocate's written opinion on the title, built on the records we pull for it.
/landlens

One Map
Every layer on one map: the parcel, its boundary, zoning, water bodies and what sits around it.
/landlens/one/map

PriceMap
What land actually changed hands for around this plot, taken from the registered deeds.
/landlens/pricemap

Build Scope
What you are allowed to build here: floor space, height, coverage and setbacks.
/landlens/build-scope

Property Tracker
Watch a property and hear about it when something new is registered against it.
/landlens/property-tracker

Deal Room
Run the transaction in one place: documents, stamping, signatures and the parties.
/landlens/deal-room

FREE TOOLS · NO ACCOUNT NEEDED

Twenty-four checks you can run yourself, at no cost.

Records and verification

The registers themselves, read for you.

- Encumbrance Certificate
- Patta and Chitta
- Field Measurement Sketch
- EC Analyzer
- Bank charge check
- Court case search
- Seller background check
- Approval check by survey

Value and duty

What it is worth and what it costs to register.

- Guideline value by street
- Guideline value by survey
- Stamp duty and registration fees
- Capital gains
- Floor space index
- Area unit converter

Zoning and land use

What the plan says can happen on this land.

- Land use zone finder
- CMDA land use check
- Coastal regulation zone
- Master plan check
- Water bodies finder
- Airport height clearance

Registers and directories

Who holds it, and which office keeps the record.

- Find your registering office
- Temple property check
- Waqf property check
- RERA register

Every free tool
/tools

Services we run for you
/services

The LandLens suite
/landlens/one

Verified RealEstate™

Every claim in this document traces back to a government record.

- Legal opinions, due diligence and title verification
- Building plan, layout and sub-division approvals
- Completion and occupancy certificates, regularisation
- Escrow, negotiation and NRI property management
- Land survey, soil testing, architecture and construction

Verified RealEstate
3/350/2 Mettukuppam,
OMR Thoraipakkam,
Chennai 600 097, India
hello@verified.realestate
+91 9996 12 9996

Prepared from the registers named on the page each finding sits on. Where a register could not be read, this document says so in its place rather than leaving the gap to be read as a clean result.